

PowerPact™ Circuit Breaker

Q-Frame Circuit Breakers

Class 0734 / Refer to Catalogs: 0734CT0201



QBL 2P
70–250 A



QBL 3P
70–250 A

POWERPACT Q-frame[▲] – 250 A, Thermal-magnetic Circuit Breaker (240 Vac)

Ampere Rating	AC Magnetic Trip Settings		B Interrupting	D Interrupting	G Interrupting	J Interrupting ★	Terminal Wire Range ■
	Hold	Trip	Catalogue Number	Catalogue Number	Catalogue Number	Catalogue Number	
2-pole, 240 Vac							
70	1000	1800	QBL22070	QDL22070	QGL22070	QJL22070	#4 AWG - 300 kcmil Al/Cu
80	1000	1800	QBL22080	QDL22080	QGL22080	QJL22080	
90	1000	1800	QBL22090	QDL22090	QGL22090	QJL22090	
100	1200	2400	QBL22100	QDL22100	QGL22100	QJL22100	
110	1200	2400	QBL22110	QDL22110	QGL22110	QJL22110	
125	1200	2400	QBL22125	QDL22125	QGL22125	QJL22125	
150	1200	2400	QBL22150	QDL22150	QGL22150	QJL22150	
175	1200	2400	QBL22175	QDL22175	QGL22175	QJL22175	
200	1200	2400	QBL22200	QDL22200	QGL22200	QJL22200	
225	1200	2400	QBL22225	QDL22225	QGL22225	QJL22225	
250	1200	2400	QBL22250■	QDL22250■	QGL22250■	QJL22250■	
3-pole, 240 Vac							
70	1000	1800	QBL32070	QDL32070	QGL32070	QJL32070	#4 AWG - 300 kcmil Al/Cu
80	1000	1800	QBL32080	QDL32080	QGL32080	QJL32080	
90	1000	1800	QBL32090	QDL32090	QGL32090	QJL32090	
100	1200	2400	QBL32100	QDL32100	QGL32100	QJL32100	
110	1200	2400	QBL32110	QDL32110	QGL32110	QJL32110	
125	1200	2400	QBL32125	QDL32125	QGL32125	QJL32125	
150	1200	2400	QBL32150	QDL32150	QGL32150	QJL32150	
175	1200	2400	QBL32175	QDL32175	QGL32175	QJL32175	
200	1200	2400	QBL32200	QDL32200	QGL32200	QJL32200	
225	1200	2400	QBL32225	QDL32225	QGL32225	QJL32225	
250	1200	2400	QBL32250■	QDL32250■	QGL32250■	QJL32250■	

▲ Replacement lugs and electrical accessories are not available for POWERPACT Q-frame circuit breakers.

■ 250 A lugs are suitable for copper conductors only.

– Refer to Catalogue 0734CT0201 for details.

Q-Frame Termination Options

Termination Letter	
A = I-Line (See Section 5)	For factory-installed termination, place termination letter in the third block of the circuit breaker catalog number. QGL32200 └ Termination Letter
E = Bolt-on I-Line (See Section 5)	
F = No lugs	
L = Lugs both ends	
M = Lugs ON end, studs on OFF end	
P = Lugs OFF end, studs on ON end	

– Add TS suffix for studs on both ends without nuts and washers. See Catalogue 0734CT0201 for additional information.

Q-Frame Interrupting Ratings (kA)

Voltage	QB	QD	QG	QJ
240 V	10	25	65	100★
480 V
600 V

★ 3-pole QJ circuit breakers are rated at 208Y/120 Vac only.

Dimensions DE3-55

Enclosures DE3-56